



✓ APPROVED (v1)
Record ID #PLM-202

PLM-02 — Gas Pressure Drop & Appliance Compliance Check (AS/NZS 56

Submitted By: Dazza - Licensed Plumber (Certifying Gasfitter)

Submitted (AEDT): 2026-10-28 09:30

Approved By: Shane Kelly (Operations Mgr)

Approved (AEDT): 2026-10-28 09:42

✓ Compliance Check: All Mandatory Controls Verified · ✓ Geo-Fence Verified Within 50m

ITEM / STANDARDIZED COMPLIANCE CHECK	RESULT / READING	STATUS
5-Minute Manometer Standing Pressure Drop Test	2.10 kPa (0.0 Drop)	✓ Verified
Commercial Rheem Manifold Operating Pressure	1.25 kPa	✓ Verified
Flue Draft & Carbon Monoxide Ambient Spill Check	2 ppm (<10 ppm)	✓ Verified
Temp & Pressure Relief (TPR) Valve Drain Line	Copper to Tundish	✓ Verified

Field Supervisor & Worker Sign-Off Notes:

Initial gas pressure & hot water manifold commissioning check (v1).