



PLM-02 — Gas Pressure Drop & Compliance Check (Amended v2) (v2)

VERSION HISTORY (v2): Supersedes v1 (09:30) — Added Tempering Valve 49.5°C verification & COC #NSW-774190.

Submitted By: Dazza - Licensed Plumber (Certifying Gasfitter)Submitted (AEDT): 2026-10-28 11:15

Approved By: Shane Kelly (Operations Mgr)Approved (AEDT): 2026-10-28 11:24

✓ Compliance Check: All Mandatory Controls Verified · ✓ Geo-Fence Verified Within 50m

ITEM / STANDARDIZED COMPLIANCE CHECK	RESULT / READING	STATUS
5-Minute Manometer Standing Pressure Drop Test	2.10 kPa (0.0 Drop)	✓ Verified
Secondary Regulator Adjusted for Peak Load Flow	1.32 kPa Stabilised	✓ Amended v2
Tempering Valve Outlet Temperature (AS/NZS 3500.4)	49.5 °C (<=50.0 °C)	✓ Amended v2
NSW Fair Trading Certificate of Compliance Number	COC #NSW-774190	✓ Verified

Field Supervisor & Worker Sign-Off Notes:

Amended v2: Added tempering valve 49.5°C reading & NSW Fair Trading COC #NSW-774190 after hot w